


INSPECTION




1. INSPECT RELAY (Marking: FAN NO. 1, FAN NO. 3)

- (a) Check the resistance of the relay.

Standard:

Tester Connection	Specified Condition
3 - 5	10 k Ω or higher
3 - 5	Below 1 Ω (when battery voltage is applied to terminals 1 and 2)

If the result is not as specified, replace the relay.




2. INSPECT RELAY (Marking: FAN NO. 2)

- (a) Check the resistance of the relay.

Standard:

Tester Connection	Specified Condition
3 - 4	Below 1 Ω
3 - 5	10 k Ω or higher
3 - 5	Below 1 Ω (when battery voltage is applied to terminals 1 and 2)

If the result is not as specified, replace the relay.



3. INSPECT ECT SWITCH (NO. 1)

- (a) Check the resistance.


Standard:

Temperature	Specified Condition
Above 98°C (208°F)	Below 1 Ω
Below 88°C (190°F)	10 k Ω or higher

If the result is not as specified, replace the switch.

NOTICE:

When checking the ECT sensor in water, the terminals should be kept dry. After the check, dry the sensor.



4. INSPECT ECT SWITCH (NO. 2)

(a) Check the resistance.

Standard:

Temperature	Specified Condition
Above 93°C (199°F)	Below 1 Ω
Below 83°C (181°F)	10 k Ω or higher

If the result is not as specified, replace the switch.

NOTICE:

When checking the ECT sensor in water, the terminals should be kept dry. After the check, dry the sensor.